

# HARRINGTON HYDRANT STORZ CONNECTIONS

**HIHS™ SPECIFICATION** The Harrington Integral Hydrant Storz is installed directly into the EJ (EJIW) hydrant and is internally secured with a setscrew. The HIHS™ meets or exceeds the requirements of AWWA C502 regarding material and pressure testing. For security, a Storz spanner wrench is required for cap removal (high-torque cap removal).

The Storz nozzle shall have a brass metal face and hard anodized 6061-T6 aluminum Storz ramps and lugs. The aluminum finish shall be hardcoat anodized to MIL-A-8625, Type 3, Class I, dark gray.

The Storz cap shall have hard anodized aluminum Storz ramps and lugs made of forged 6061-T6 aluminum. The center cap shall be forged 6061-T6 aluminum. The Storz Cap shall be connected to the hydrant with a 0.125" vinyl coated stainless steel aircraft cable and (2) aluminum crimps. As a security consideration, the HIHS™ Storz cap requires a Storz spanner wrench for removal. However, the Storz Hose Coupling will connect quickly and easily by hand.

**The HIHS™ is completely Made In USA**


Once installed, the HIHS™ **extends only 1.75"** from the hydrant nozzle.

**Specify HARRINGTON STORZ**

**"HIHS-EJIW-50-45"**


**- 250 psi working pressure**

**- MADE IN USA**



**Harrington, Inc.**  
2630 W. 21st St.  
Erie, PA 16506

Ph. 800-553-0078  
daveh@harrinc.com



|   |         |                          |      |
|---|---------|--------------------------|------|
| DWG No.: <b>HIHS-EJIW-50-45</b>   |         |                          |      |
| 5" Storz Integral Hydrant Nozzle: 5 x EJ (EJIW)<br>4½" nozzle with Storz Cap and SS Cable |         |                          |      |
| Date: 07/01/18  | DB: DTH | Harrington Hydrant Storz |      |
| Not to scale  |         | Sheet 1 of 1             | HIHS |